

## INSTRUMENTATION

### ACCIDENT MONITORING INSTRUMENTATION

#### LIMITING CONDITION FOR OPERATION

3.3.3.6 The accident monitoring instrumentation channels shown in Table 3.3-10 shall be OPERABLE.

#### APPLICABILITY MODES 1, 2, and 3.

#### ACTION:

- a. With the number of OPERABLE accident monitoring channels less than the Required Number of Channels shown on Table 3.3-10, either restore the inoperable channel(s) to OPERABLE status within 30 days or submit a Special Report within the following 14 days from the time the action is required. The report shall outline the preplanned alternate method of monitoring, the cause of the inoperability, and the plans and schedule for restoring the instrumentation channels to operable status.
- b.1 With the number of OPERABLE Reactor Building radiation monitoring channels less than the Minimum Channels Operable requirement of Table 3.3-10, either restore the inoperable channel(s) to OPERABLE status within 72 hours, or:
  - i) Initiate the preplanned alternate method of monitoring the appropriate parameter(s), and
  - ii) Submit a Special Report to the Commission pursuant to Specification 6.9.2 within 14 days following the event outlining the action taken, the cause of the inoperability, and the plans and schedule for restoring the system to OPERABLE status.
- b.2 With the number of Hydrogen monitoring channels less than the Minimum Channels Operable requirement of Table 3.3-10, restore at least one monitor to operable status within 72 hours or be in at least HOT STANDBY within the next 6 hours, and in HOT SHUTDOWN within the next 12 hours.
- b.3 With the number of OPERABLE accident monitoring channels less than the Minimum Channels Operable requirement of Table 3.3-10, either restore the inoperable channels to OPERABLE status within 7 days or be in at least HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the next 12 hours.
- c. The provisions of Specification 3.0.4 are not applicable.

#### SURVEILLANCE REQUIREMENTS

4.3.3.6 Each accident monitoring instrumentation channel shall be demonstrated OPERABLE by performing a monthly CHANNEL CHECK and a CHANNEL CALIBRATION every refueling outage. The Reactor Building Radiation Level Instrumentation CHANNEL CALIBRATION may consist of an electronic calibration of the channel, not including the detector, for the range decades above 10R/hr and a single point calibration of the detector below 10R/hr with an installed or portable gamma source.

9407290354 940722  
PDR ADOCK 05000395  
P PDR