

CONTROL BLOCK:

--	--	--	--	--	--	--

 (1)

0	1	N	C	B	E	P	Z	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5			
7	8	LICENSEE CODE							14	LICENSE NUMBER											25	LICENSE TYPE					30	CAT 58				

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 | During the ongoing 1982 refueling outage, while performing friction testing of
0 3 | control rods, it was discovered that rod 06-23 did not have RTGB indication at pos-
0 4 | itions 20, 21, 24, 25, 28, 32, 33, 36, 37, and 39, and that rod 26-27 did not have
0 5 | RTGB indication at positions 12, 13, 16, 17, and 19. These rods were then fully
0 6 | inserted in accordance with technical specifications. This event did not affect the
0 7 | health and safety of the public.

Technical Specifications 3.1.3.7b, 6.9.1.9b

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE								
0	9	I	B	11	A	12	F	13	Z	Z	Z	Z	Z	Z	14	Z	15	Z	16			
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26			
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.												
17	8	2	21	22	23	0	8	1	24	25	26	27	0	3	28	29	30	L	31	0	32	
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER						
X	18	G	19	Z	20	Z	21	0	0	0	22	N	23	Y	24	N	25	G	0	8	0	26
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	

1 0 During the ongoing outage, after rebuilding the HCU to each subject rod, contract

1 1 personnel failed to properly reconnect the rod position indication probe connectors.

1 2 The connectors to all HCUs rebuilt in 1982 were checked and tightened as required.

1 3 Applicable maintenance instructions will be revised to ensure these connectors are

1 4 manipulated only by CP&L I&C personnel.

8 9 FACILITY STATUS 1 5 H (28) 2 8 9 10 11 12 13 % POWER 0 0 0 (29) 14 15 16 17 18 19 20 21 22 23 24 25 26 27 OTHER STATUS (30) NA 34 35 36 37 38 39 40 41 42 43 METHOD OF DISCOVERY (31) A 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 DISCOVERY DESCRIPTION (32) Operator Surveillance 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 34

7 8 9 10 11

AMOUNT OF ACTIVITY (35) NA

44

LOCATION OF RELEASE (36) NA

45 80

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) NA				

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

1		9		Z		42		DESCRIPTION		NA	
7	8	9	10	11	12	13	14	15	16	17	18

PUBLICITY
ISSUED N(44) DESCRIPTION (45)
PDR ADOCK 05000324 PDR
S

NRC USE ONLY

68 69 80

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521