LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(1) [A][L][J][M][F][1] (2) LICENSEE CODE [0][0]-[0][0][0][0][0]-[0][0] (3) LICENSE NUMBER [4][1][1][1][1] (4) LICENSE TYPE (5) CAT

REPORT SOURCE [L] (6) [0][5][0][0][0][3][4][8] (7) DOCKET NUMBER [0][6][2][6][8][2] (8) EVENT DATE [0][7][2][2][8][2] (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

At 1410 on 6/26/82 during the performance of FNP-1-STP-20.0 (Penetration Room Filtration System Train A Operability and Valve Inservice Test), the "A" Train Penetration Room Filtration System was declared inoperable when the main control board handswitch for the recirculation fan suction damper (3362A) fractured. Tech. Spec. 3.7.8, in part, requires this penetration room filtration system to be operable. Tech. Spec. 3.7.8 action statement requirements were met. Health/Safety of the public was not affected.

SYSTEM CODE [A][A] (11) CAUSE CODE [E] (12) CAUSE SUBCODE [C] (13) COMPONENT CODE [C][K][T][B][R][K] (14) COMP. SUBCODE [E] (15) VALVE SUBCODE [Z] (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR [8][2] — SEQUENTIAL REPORT NO. [0][3][4] / OCCURRENCE CODE [0][3] REPORT TYPE [L] — REVISION NO. [0]

ACTION TAKEN [C] (18) FUTURE ACTION [Z] (19) EFFECT ON PLANT [Z] (20) SHUTDOWN METHOD [Z] (21) HOURS [0][0][0][0] (22) ATTACHMENT SUBMITTED [N] (23) NPRD-4 FORM SUB. [N] (24) PRIME COMP. SUPPLIER [N] (25) COMPONENT MANUFACTURER [X][9][9][9]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

This event was due to a broken shaft in the main control board handswitch. Following the replacement of the handswitch, "A" train penetration room filtration system was declared operable at 1830 on 6/26/82.

FACILITY STATUS [E] (28) % POWER [1][0][0] (29) OTHER STATUS (30) NA METHOD OF DISCOVERY [A] (31) DISCOVERY DESCRIPTION (32) Operational Event

ACTIVITY RELEASED [Z] (33) CONTENT OF RELEASE [Z] (34) AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES NUMBER [0][0][0] (37) TYPE [Z] (38) DESCRIPTION (39) NA

PERSONNEL INJURIES NUMBER [0][0][0] (40) DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY TYPE [Z] (42) DESCRIPTION (43) NA

PUBLICITY ISSUED [N] (44) DESCRIPTION (45)

8208020122 820722
PDR ADOCK 05000348
S PDR

NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III PHONE: (205) 899-5156