

1150-0011  
EXPIRES 4-30-82

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38

0 1 S C N E E 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

L I C E N S E 延 展 C O D 延 展 C O D 延 展 N U M 延 展 N U M 延 展 T Y P E 延 展 T Y P E 延 展 C A T 延 展

0 1 REPORT SOURCE L 6 0 5 0 0 0 2 6 9 7 0 6 2 3 8 2 8 0 7 2 1 8 2 9  
7 8 60 61 DOCKY NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

02 On June 23, 1982 both trains of Reactor Building Spray (RBS) were inoperable due  
03 to the B train RBS pump being out of service while the A train RBS pump suction  
04 valve was shut. The Reactor Building Cooling System was operable, and capable of  
05 limiting containment pressure below design pressure during a LOCA; thus, the  
06 health and safety of the public were not affected by this incident.

0	7	
0	8	

[illegible]

1 0 | The cause of this incident was personnel error. The B train was made operable  
1 1 | by racking in the RBS pump breaker. The Assistant Shift Supervisor was counseled  
1 2 | regarding his error, and all operators will review this incident.

1	3	
1	4	

1 5 E 28 1 0 0 29 NA 30 31 A 32 Operator Observation

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) NA NA

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION
1	7	0 0 0	(37) Z	(38) NA

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

1. LOSS OF OR DAMAGE TO FACILITY		2. TYPE		3. DESCRIPTION		4. (43)	
1	9	Z	(2)	NA			

PRIORITY (45) 8208020164 820721  
 ISSUED DESCRIPTION PDR ADOCK 05000269  
 2 0 N 44 N S PDR  
 NRC USE ONLY

PHONE: (704) 373-7139