

CAR 1393

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N Y R E G I 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 L 6 0 5 0 - 2 4 4 4 7 0 6 2 2 8 2 8 0 7 2 4 8 2 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 While at steady state 100% operation, a periodic test identified the containment
03 gas radiation monitor reutrn line check valve was not sealing tight. This is
04 reportable under Tech Spec 6.9.2.b.2. This is the same valve that failed on LER
05 81-021 and LER 82-011.
06
07
08

09 B B 11 E 12 X 13 V A L V E X 14 C 15 A 16
7 8 9 10 11 12 13 18 19 20
17 8 2 0 1 5 0 3 L 0
21 22 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
X 18 F 19 Z 20 Z 21 0 0 0 0 22 N 23 N 24 L 25 R 3 4 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 Dirt possibly from the veins of the monitor pump deposited on the seat of the carbon
11 steel Rockwell 2" 600 psi. Air was blown through the valve to clear it out. After
12 the last failure, the valve was replaced with this bolted bonnet check valve.
13 Modifications are being expedited to install a filter in this line.
14

15 E 28 1 0 0 29 NA B 31 Periodic Testing of Check Valve
7 8 9 10 12 13 44 45 46 80
ACTIVITY CONTENT RE RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
16 Z 33 Z 34 NA NA
7 8 9 10 11 44 45 80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
17 0 0 0 37 Z 38 NA
7 8 9 11 12 13 80
PERSONNEL INJURIES NUMBER DESCRIPTION
18 0 0 0 40 NA
7 8 9 11 12 80
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
19 Z 42 NA
7 8 9 10 80
PUBICITY ISSUED DESCRIPTION
20 Z 44 NA
7 8 9 10 80

8208020321 820724
PDR ADOCK 05000244
S PDR

NRC USE ONLY

NAME OF PREPARER S. M. Spector

PHONE 315-524-4446 Ext. 214