

LASALLE COUNTY NUCLEAR GENERATING STATION
N.P.D.E.S. PERMIT NO: IL0048151
NONCOMPLIANCE REPORT

DISCHARGE NUMBER AND DESCRIPTION: 001c - Low Volume Waste
Wastewater Treatment Facility.

PARAMETER AND PERMIT LIMIT: Oil and Grease, 15 mg/l

NONCOMPLIANCE, DATE, AND DURATION:

18 mg/l, June 1, 1982, Unknown

CAUSE OF NONCOMPLIANCE:

Review of operator logs and round sheets, does not indicate a cause for this result. Review of pH, total metals, and total suspended solids analyses performed concurrently do not indicate a system problem. An error in the sampling or the analysis is suspected. Since insufficient sample was obtained to re-analyze, the Station cannot verify at this time.

CORRECTIVE ACTION:

An oil-soak boom has been placed into the outlet chamber of the Wastewater Treatment Facility. This boom should prevent residual oil from being discharged. Also, a duplicate grab sample for oil and grease will be obtained to allow for reanalysis, if desired, to pinpoint analytical discrepancies.

DATE RECOGNIZED AS A VIOLATION:

12JUL82

DATE INVESTIGATED:

12JUL82

8208020357 820714
PDR ADOCK 05000373
S PDR