

Certified By McL**BALTIMORE GAS AND ELECTRIC COMPANY**

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT  
CALVERT CLIFFS NUCLEAR POWER PLANT  
LUSBY, MARYLAND 20637

July 19, 1982

Mr. Ronald C. Haynes, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, PA. 19406

Docket No. 50-317  
License No. DPR-53

SUBJECT: LER 82-35, Unit 1


Dear Mr. Haynes

This letter is to confirm our verbal notification of your Mr. Ralph Architzel of the discovery that the level in one safety injection tank was found to be below minimum Technical Specification Limits.

At 0015 on 7-17-82 with Unit 1 in Mode 1, it was discovered that 11B safety injection tank level indicated 192 inches on the narrow range indicator, but only 180 inches on the wide range indicator. The Technical Specification Limit is 187 inches. While the operator was investigating the discrepancy, the narrow range indicator decreased below the minimum scale reading of 184 inches. This is a violation of Technical Specification 3.5.1.b. Water was added to the tank and minimum level achieved at 0108, terminating the event.

A complete description of the events leading to this discovery and further corrective actions will be addressed in the follow-up report.

Very truly yours,



L. B. Russell  
Plant Superintendent

LBR:fld

cc: J. A. Tiernan  
Director, Office of Management  
Information & Program Control  
G. S. Pavis

R. M. Douglass  
R. E. Architzel  
L. B. Russell