

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY  
STATION MANAGER

RECEIVED  
NRC

1982 JUL 26 PM 12:39

SCE

REGION VIES

TELEPHONE  
(714) 492-7700

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Administrator

Dear Sir:

Subject: Docket No. 50-361  
30-Day Report  
Licensee Event Report No. 82-033  
San Onofre Nuclear Generating Station, Unit 2

Reference: Letter, H. B. Ray (SCE) to R. H. Engelken (NRC),  
dated July 2, 1982

The referenced letter confirmed our prompt notification of your office of our failure to provide Licensee Event Reports (LER's) within 30 days of the dates upon which the event had occurred.

Pursuant to Appendix A Technical Specification 6.9.1.13.b to Operating License NPF-10 for San Onofre Unit 2 this submittal provides the required 30-day written report and a copy of LER form, for an occurrence involving the Turbine Overspeed Protection System (TOPS).

On June 9, 1982 while in Mode 3, work was authorized to clean spilled oil and locate and repair leaks in the electro hydraulic actuation portion of the TOPS. This rendered the System inoperable. Technical Specification 3.3.4 requires that at least one Turbine Overspeed Protection System be operable. The associated Action b. requires that the turbine be isolated from the steam supply within six hours. Isolation was achieved because the MSIV's and Turbine Stop Valves were closed at that time.

The cause of the event was maintenance being performed to repair oil leaks on the unitized actuator. The immediate corrective action was in place as the MSIV's and Turbine Stop Valves were closed. No additional corrective actions are needed.

8208020414 820722  
PDR ADDCK 05000361  
S PDR

IE-29

Mr. R. H. Engelken

- 2 -

July 22, 1982

Since there is no decay heat in the core and the MSIV's were closed, there was no effect on public health and safety as a result of this event.

Should you require additional information concerning this incident, please contact me.

Sincerely,

*HB Day met for HB Day*

Enclosure

cc: U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission  
Office of Management Information and Program Control

Institute of Nuclear Power Operations (INPO)

A. E. Chafee (USNRC Resident Inspector, San Onofre Unit 1)