

LICENSEE EVENT REPORT

Attachment to AECM-82/413

Page 1 of 1

CONTROL BLOCK:

--	--	--	--	--	--

1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	LICENSE NUMBER										25	LICENSE TYPE					30	CAT 58				

CON'T

0 1 7 8

REPORT SOURCE L 6 0 5 0 0 0 4 1 6 7 0 8 2 2 8 2 8 0 9 2 0 8 2 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 The smoke detector zone covering the motor control center area and south hallway
0 3 elevation 119 ft. of the Auxiliary Building gave erroneous alarms intermittently. The
0 4 fire zone was deactivated and fire watch established in accordance with T.S.3.3.7.9.
0 5 The motor control center area is provided with automatic sprinkler coverage and the
0 6 zone smoke detectors provide early warning signals. There was no effect on public
0 7 health and safety. There was no threat to plant safety as a continuous fire watch
0 8 was in effect.

0 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE						COMP. SUBCODE		VALVE SUBCODE			
7	8	A	B	11	X	12	Z	13	I	N	S	T	R	U	14	E	15	Z	16
		9	10		11	12	12	13	13					18	19		20		
17		EVENT YEAR				SEQUENTIAL REPORT NO.				OCCURRENCE CODE		REPORT TYPE				REVISION NO.			
LER/RO REPORT NUMBER		8	2	—		0	5	3	/		0	3	L	—		0			
		21	22	23		24	26	27			28	29	30	31		32			
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER			
E	H	Z		Z		0		0	0	N	N		X	H		2	6	0	
33	34	35		36		37		40	41	42	43	44	47		48		49		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The intermittent alarm was attributed to noise in the system. No circuit problem was
1 1 discovered by maintenance personnel responding to investigate. The zone was returned
1 2 to service on August 26, 1982. Repetitive occurrences of this nature will be tracked
1 3 and reviewed for further corrective action. This is intended as a final report.

1
4
7
8
9
80

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	G	28	0	0	0	29	NA	A	31	Alarmed Condition			

Figure 1 is a schematic representation of the data structure of the 100-item test. It shows a sequence of items numbered 1 to 100. The items are grouped into three main categories: 'ACTIVITY RELEASED' (items 1-10), 'AMOUNT OF ACTIVITY' (items 11-44), and 'LOCATION OF RELEASE' (items 45-80). The items are represented by boxes containing numbers, with some boxes labeled 'NA' (Not Applicable). The diagram also includes labels for 'CONTENT OF RELEASE' and 'ACTIVITY RELEASED'.

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	(38)	NA	(39)	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	2	0	0	0	NA

		LOSS OF OR DAMAGE TO FACILITY		(43)
		TYPE	DESCRIPTION	
7	8	9	10	80
1	9	Z	(42) NA	

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 N (44) 8209240218 820920
 PDR ADOCK 05000416
 S PDR
 NFC USE ONLY
 68 69 80

NAME OF PREPARER Original Signed by D. L. Pace

PHONE: _____

590 917-926