

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

May 26, 1983

Director of Nuclear Reactor Regulation  
Attention: Ms. E. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of ) Docket Nos. 50-327  
Tennessee Valley Authority ) 50-328

The Sequoyah Nuclear Plant unit 1 operating license condition 2.C.(8) requires TVA to reinspect the low pressure turbine disks for cracks before startup after the second refueling outage. We performed an inspection during the unit 1, cycle 1 refueling outage. The inspection revealed four minor indications of which no indication of any radial depth was found. The evaluation of these four indications, by TVA and Westinghouse Electric Corporation, has determined these indications to be assembly scratches or tool marks, and not cracks. These inspection records are on file and are available for inspection at your convenience. Accordingly, we consider this license condition to be satisfied by this inspection and notification of the results provided by this letter.

If you have any questions concerning this matter, please get in touch with Jerry Wills at FTS 858-2683.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*L. M. Mills*  
L. M. Mills, Manager  
Nuclear Licensing

Sworn to and subscribed before me  
this 26th day of May 1983

*Paulette H. White*  
Notary Public  
My Commission Expires 9-5-84

cc: U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, NW  
Suite 2900  
Atlanta, Georgia 30303

8305310077 830526  
PDR ADOCK 05000327  
PDR

A001  
1/0