

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

May 24, 1983

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
Attn: Mr. Robert A. Clark, Chief  
Operating Reactors Branch No. 3  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Serial No. 293  
NO/JHL:acm  
Docket No. 50-339  
License No. NPF-7

Gentlemen:


VIRGINIA ELECTRIC AND POWER COMPANY  
NORTH ANNA POWER STATION UNIT NO. 2  
BACKUP OVERCURRENT PROTECTION SYSTEM

North Anna Unit 2 License Condition 2.C(10) states, "No later than October 11, 1980, Vepco shall submit a design for the backup overcurrent protection system for containment electrical penetrations for commission review and approval. The backup system shall be installed and operational prior to resuming power operation following the second refueling outage."

North Anna Unit 2 has completed its second refueling outage. During this second refueling outage, the backup overcurrent protection system for containment electrical penetrations was installed. This system is now considered operational.

North Anna Unit 2 License Condition 2.C(10) is complete. A seismic design verification program is currently in progress for the backup overcurrent protection equipment for the containment air recirculation fans, the inside recirculation spray pumps and the pressurizer heaters.

Very truly yours,

  
W. L. Stewart

cc: Mr. James P. O'Reilly  
Regional Administrator  
Region II

Mr. M. B. Shymlock  
NRC Resident Inspector  
North Anna Power Station

8305310099 830524  
PDR ADOCK 05000339  
P PDR

*Avol*  
*1/0*