PUBLIC SERVICE COMPANY OF COLORADO
P. O. BOX 840 DENVER, COLORADO 80201

OSCAR R. LEE
VICE PRESIDENT

RECEIVED
AUG 23 1982

August 6, 1982
Fort St. Vrain
Unit No. 1
P-82301

Mr. John T. Collins
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76012

SUBJECT: Docket No. 50-267/82-17

Dear Mr. Collins:

This letter is in response to the Notice of Violation received as a result of the Resident Inspector's inspection for the period of June 1st thru June 30th, 1982, wherein the violation was noted:

Technical Specification 7.4.a, "Procedures, Administrative controls," states in part that, "... written procedures shall be established, implemented, and maintained...."

Administrative Procedure P-8, "Fire Prevention and Fighting," Issue 4, dated March 31, 1982, Section 4.4.4, states in part that:

> "f) The temporary use of combustibles in safety-related areas must be controlled. Such material may be allowed into safety-related areas only when immediate use is intended, and must be removed from the area when not being used."

Contrary to the above, on June 15, 1982, at approximately 2:00 p.m. MDT, the NRC inspector determined that the unattended can of combustible material, which was found in a safety-related area (reactor building), was not controlled since the licensee had not authorized its use and was not aware of who was using it.

(1) The corrective steps which will be taken and the results achieved:

A memo reviewing the requirements to control combustible material has been posted on the Construction bulletin board and discussed with the Construction Superintendent. In addition, the spray cans will be issued only after superintendent approval and will be signed out of and back into the Construction Tool Room by the individual using the material. These steps have established the control of combustibles in safety related areas.

8209270229 820915
PDR ADOCK 05000267
Q PDR

(2) The corrective steps which will be taken to avoid further violations:

The action notes in Item 1 should prevent further reoccurrences.

(3) The date when full compliance will be achieved:

June 16, 1982

If you have any further questions please contact William Franek at (303) 785-1403 for further information.

Very truly yours,

Oscar R. Lee
Vice President,
Electrical Production

ORL/WJF/scp

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter	)	
	)	
Public Service Company of Colorado	)	Docket No. 50-267
Fort St. Vrain Unit No. 1	)	

AFFIDAVIT

. . . . . being duly sworn, hereby deposes and says that he is Vice President of Electrical Production of Public Service Company of Colorado; that he is duly authorized to sign the file with the Nuclear Regulatory Commission the attached response to the Notice of Violation identified in NRC Inspection Report 82-17; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information and belief.

ORLee
O. R. Lee
Vice President of Electrical Production

STATE OF Colorado)
) ss
COUNTY OF Weld)

Subscribed and sworn to before me, a Notary Public in and for the State of Colorado on this 6th day of August, 1982.

Audrey L. Kitzman
Notary Public

My commission expires 11-29, 1983