

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDC 2 7 00-000000-00 3 41111 4 5
 1 8 9 14 15 25 26 30 35
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 55
 CON'T

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 1 6 7 0 5 0 3 8 3 8 0 5 2 7 8 3 9

60 61 DOCKET NUMBER 65 69 EVENT DATE 74 75 REPORT DATE 80

NT DESCRIPTION AND PROBABLE CONSEQUENCES

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING A SURVEILLANCE TEST ON THE SOLID STATE PROTECTION SYSTEM (TRAIN B), A LOGIC

0 3 | TEST POSITION TESTED UNSATISFACTORILY. THIS AFFECTED THE POWER RANGE HIGH FLUX RATE

0 4 | TRIP PORTION OF THE AUTOMATIC LOGIC, TECHNICAL SPECIFICATION TABLE 3.3-1 ITEM 22.

0 5 | THE REQUIREMENTS OF THE ACTION ITEM WERE MET. THE PUBLIC HEALTH AND SAFETY WERE NOT

0 6 | AFFECTED. PREVIOUS OCCURRENCES INCLUDE: 050-315/78-067, 81-043 AND 50-316/78-076,

0 7 | 82-056, 83-033, 038.

SYSTEM CODE I B 11		CAUSE CODE E 12		CAUSE SUBCODE G 13		COMPONENT CODE I N S T R U 14		COMP SUBCODE X 15		VALVE SUBCODE Z 16	
EVENT YEAR 8 3 17		SEQUENTIAL REPORT NO. 0 4 7 18		OCCURRENCE CODE 0 3 19		REPORT TYPE L 20		REVISION NO. 0 21		COMPONENT MANUFACTURER W 1 2 0 22	
ACTION TAKEN A 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)		NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER N 25							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

UNIVERSAL CARD A-212 (WESTINGHOUSE, PART NO. 6056D21G01) WAS FOUND TO HAVE FAILED.

THE LOGIC CARD WAS REPLACED, THE SURVEILLANCE TEST WAS PERFORMED ON TRAIN "B" TO

VERIFY SYSTEM OPERABILITY. NO FURTHER ACTION IS PLANNED.

8 9
FACILITY STATUS (5) [E] (28) 1 10 10 (29) NA OTHER STATUS (30) METHOD OF DISCOVERY (31) [B] SURVEILLANCE TEST DISCOVERY DESCRIPTION (32) 80

8 9 10 11 12 13 14
ACTIVITY CONTENT RELEASED OF RELEASE (6) [Z] (33) [Z] (34) AMOUNT OF ACTIVITY (35) NA LOCATION OF RELEASE (36) 80

8 9 10 11 12 13 14
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (37) [Z] (38) NA 80

8 9 10 11 12 13 14
PERSONNEL INJURIES NUMBER DESCRIPTION (40) NA 80

8 9 10 11 12 13 14
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (42) NA 80

8 9 10 11 12 13 14
PUBLICITY ISSUED DESCRIPTION (44) [N] (45) 80

8306060271 830527
PDR ADOCK 05000316
S PDR

NRC USE ONLY

NAME OF PREPARER R. A. PALMER

PHONE (616) 465-5901