


Southern California Edison Company



P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

J. G. HAYNES
MANAGER OF NUCLEAR OPERATIONS

June 3, 1983

TELEPHONE
(213) 572-1742

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. John B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

As requested, this letter provides our response for San Onofre Units 2 and 3 to IE Bulletin No. 83-03: Check Valve Failures in Raw Water Cooling Systems of Diesel Generators.

The diesel generator cooling water systems at San Onofre Units 2 and 3 have been reviewed, and it has been determined that there is no check valve in the these systems. The diesel generator cooling water systems are corrosion inhibited closed loops which reject heat through fan cooled radiators. As these systems are not raw water cooling systems, and do not utilize check valves, IE Bulletin 83-03 is not applicable to San Onofre Units 2 and 3 and no further action related to this Bulletin is being taken.

Subscribed on this 3rd day of June, 1983.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By: J. G. Haynes
J. G. Haynes
Manager of Nuclear Operations

8306070029 830603
PDR ADOCK 05000361
Q PDR

Subscribed and sworn to before me this
3rd day of June, 1983.

Agnes Crabtree
Notary Public in and for the County of
Los Angeles, State of California

My Commission Expires: Aug 27, 1986



cc: Document Control Desk, NRC
(Washington D. C.) (Original)
A. E. Chaffee, USNRC
Site Inspector, S023

IE 11
110