



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 4, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Inoperable Smoke Detectors  
Reference: LER 82-071/03 L-0  
AECM-82/438

82 OCT 5  
ALL  
REGIONAL  
ATLANTA, GEORGIA

On September 3, 1982, smoke detectors in three fire zones alarmed with no fire or fumes present. The smoke detectors were deactivated and a fire watch was established pursuant to T.S.3.3.7.9. Attached is LER 82-071/03 L-0.

Yours truly,

*J.P. McGaughy*  
for J.P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8210080120 821004  
PDR ADOCK 05000416  
S PDR

OFFICIAL COPY

IE 22