



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 25, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-037/0 - Fire
Doors 1A214 and 1A210
Opened to Allow Routing of
Air Hoses
AECM-83/0300

On April 21, 1983, fire doors 1A214 and 1A210 were opened to allow the routing of air hoses into the adjacent Motor Control Center Division I switchgear rooms to perform a planned maintenance activity (cleaning of Division I Motor Control Center's) during the planned Division I electrical outage. All fire rated doors are required to be closed at all times by Technical Specification 3.7.7 and since the doors were not closed by the LCO time limit of 7 days this is being submitted as a Special Report pursuant to Technical Specification 6.9.2.

The doors were secured on May 9, 1983, at 2330 hours. The event had no affect on the health and safety of the public and did not constitute a threat to plant safety. This is a final report.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap

cc: (See Next Page)

8306070142 830525
PDR ADDCK 05000416
S PDR

83 JUN 1 PIG: 59

USNRC REGION II
ATLANTA, GEORGIA

OFFICIAL COPY

EE 22

110

MISSISSIPPI POWER & LIGHT COMPANY

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555