



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 5, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Smoke Detector Inoperability  
Reference: LER 82-066/03 L-0  
AECM-82/439

On September 9, 1982, the smoke detector zone covering the hallway area at (elevation 93) and the HPCS pumproom of the Auxiliary Building alarmed and would not clear. No smoke or fire was revealed. A Limiting Condition for Operation was entered pursuant to T.S.3.3.7.9. Attached is LER 82-066/03 L-0.

Yours truly,

*L. J. DeLoach*  
for J. P. McGaughy

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8210080284 821005  
PDR ADDCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY  
LE 22