



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 25, 1983

USNRC REGION 1
ATLANTA, GEORGIA

8 JUN 3 P10:55

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-036/0 - Fire
Rated Penetration DE-20A
Opened to Route a Temporary
Cable
AECM-83/0301

On April 18, 1983, fire rated penetration DE-20A located between the Division I and Division II diesel generator bays was opened to route a temporary cable used to supply temporary power to the Division I lighting transformer 1X113 during a planned Division I electrical outage. This required entering action statement (a) of Technical Specification 3.7.7.

The penetration was not sealed within 7 days, therefore, this is submitted as a Special Report pursuant to Technical Specification 6.9.2. This event had no affect the health and safety of the public and did not constitute a threat to plant safety. The estimated date for restoration is June 15, 1983.

Yours truly,

J. P. McGaughy, Jr.
for J. P. McGaughy, Jr.

JPM:sap

cc: (See Next Page)

OFFICIAL COPY

8306070230 830525
PDR ADDCK 05000416
S PDR

IE 22

1/0

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0301

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555