

LICENSEE EVENT REPORT

Update Report:

Previous Report Date: 04-18-83

CONTROL BLOCK:

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE				30	57	CAT	58	

CON'T

REPORT SOURCE L 0 5 0 - 0 3 2 4 7 0 3 1 3 8 3 8 0 5 3 1 8 3 9
 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During plant operation performance of Suppression Pool Level Indicators Operability

0 3 | Test, PT-03.1.6, revealed that indicator/recorder 2-CAC-LR-2602 was shewing an out-

0 4 | of-specification low level while the redundant level indicators showed a normal level.

0 5 | This event did not affect the health and safety of the public.

0 6 | Technical Specifications 3.3.5.3, 6.9.1.9b

0 7 |

0 8 |

SYSTEM CODE I E 11		CAUSE CODE B 12		CAUSE SUBCODE A 13		COMPONENT CODE I N S T R U 14				COMP. SUBCODE T 15		VALVE SUBCODE Z 16	
ACTION TAKEN X 18		FUTURE ACTION C 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED Y 23		NPRD-4 FORM SUB. Y 24	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 3 21 22		SEQUENTIAL REPORT NO. 0 2 6 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 2 32		PRIME COMP. SUPPLIER N 25	
COMPONENT MANUFACTURER B 0 4 C 26													

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The LR-2602 instrument transmitter, LT-2602, was found operating out of calibration tolerances. The transmitter, Model No. BQ15221, was calibrated, the PT was satisfactorily completed, and LR-2602 was returned to service.

1 1

1 2

1 3

1 4

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (28) E

% POWER (29) 1 0 0

OTHER STATUS (30) NA

METHOD OF DISCOVERY (31) B

DISCOVERY DESCRIPTION (32) Periodic Test

ACTIVITY CONTENT
RELEASED OF RELEASE

1	6	2	33	4	34
7	8	9	10	11	12

AMOUNT OF ACTIVITY

NA

35

LOCATION OF RELEASE

NA

36

45

8

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)		NA

PERSONNEL INJURIES										
NUMBER				DESCRIPTION						
1	8	0	0	0	40	NA				

		LOSS OF OR DAMAGE TO FACILITY		(43)	
TYPE		DESCRIPTION			
1	9	Z	(42)		NA

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 N (44) PDR ADDCK 05000324
 S PDR
 NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr.

PHONE: 919-457-9521



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

May 31, 1983

FILE: B09-13510C
SERIAL: BSEP/83-1670

Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
SUPPLEMENT TO LICENSEE EVENT REPORT 2-83-26

Dear Mr. O'Reilly:

In accordance with Section 6.9.1.9b of the Technical Specifications for Brunswick Steam Electric Plant, Unit No. 2, the enclosed supplemental Licensee Event Report is submitted. The original report fulfilled the requirement for a written report within thirty (30) days of a reportable occurrence and both are in accordance with the format set forth in NUREG-0161, July 1977.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/shb/LETSHB

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

83 JUN 3 P10:54
USNRC REGION II
ATLANTA, GEORGIA

OFFICIAL COPY

LE22

//

LER ATTACHMENT - RO #2-83-26

Facility: BSEP Unit No. 2

Event Date: March 13, 1983

As a result of an event involving this instrumentation on Unit No. 1, as reported in LER 1-81-07, and a post-TMI requirement, plant modification packages (80-79 and 80-016 for Unit No. 1 and 80-78 and 80-017 for Unit No. 2) have been developed. These modifications will install condensing pots in the reference legs of these instruments in order to increase their accuracy and reliability, and remove the requirement to have flow in their reference legs to ensure they are full.