


LICENSEE EVENT REPORT

Attachment to AECM-83/0255

Page 1 of 1

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

0 1 M S G G S 1 2 0 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

REPORT SOURCE 01 L 6 0 5 0 0 0 4 1 6 7 0 1 3 1 8 3 8 0 5 0 9 8 3 9
7 8 60 61 DOCKET NUMBER 66 66 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On January 31, 1983, maintenance began opening eight penetrations in the Control Bldg. to allow conduit routing. This is in accordance with design change package 82/5118. The penetrations are being opened one at a time. The event has no effect on the health and safety of the public and does not constitute a threat to plant safety. The event requires entering an action statement for T.S.3.7.7 and is being reported pursuant to T.S.6.9.1.13.b.

SYSTEM CODE A B (11)		CAUSE CODE X (12)		CAUSE SUBCODE Z (13)		COMPONENT CODE Z Z Z Z Z Z (14)				COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)			
7 8		9 10		11 12		13 14 15 16 17 18				19 20		21 22			
(17) LER RO REPORT NUMBER		EVENT YEAR 8 3 (21) (22)		SEQUENTIAL REPORT NO. 0 4 1 (24) (25) (26)		OCCURRENCE CODE / 0 3 (27) (28) (29)				REPORT TYPE X (30)		REVISION NO. 1 (31) (32)			
ACTION TAKEN Z (18)		FUTURE ACTION X (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22) (23) (24) (25)				ATTACHMENT SUBMITTED N (26)		NPRD-4 FORM SUB. N (27)	
33 34		35 36		37 38 39 40		41 42		43 44 45 46 47				48 49			
PRIME COMP. SUPPLIER Z (25)		COMPONENT MANUFACTURER Z 9 9 9 (26) (27) (28) (29)													

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause is due to planned maintenance. An hourly fire watch is being
1 1 conducted on each penetration as it is opened. The penetrations are
1 2 expected to be restored by June 30, 1983. This is a final report.
1 3
1 4

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	8	0	0	0	NA	A	Planned Maintenance						
ACTIVITY CONTENT			AMOUNT OF ACTIVITY			LOCATION OF RELEASE								
1	6	Z	Z	NA										

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	2	0	0	0	NA

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE		DESCRIPTION
1	9	7
2	42	NA

8306070237 830509

80

PUBLICITY
ISSUED DESCRIPTION (45)
[2] [0] [N] (44) NA
PDR ADOCK 05000416 PDR
S
NRC USE ONLY

NAME OF PREPARER

M. V. Rohrer

PHONE

NAC USE ONLY

026-7 16 045



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 9, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Penetrations
Opened for Routing Conduit
in the Control Building
LER 83-041/99 X-1
AECM-83/0255/63

This is an update to a previous report submitted on March 1, 1983. The event for which the report was submitted occurred on January 31, 1983, when maintenance began opening eight penetrations in the Control Building to allow conduit routing. The penetrations are being opened one at a time. An hourly fire watch is being conducted on each penetration as it is opened in accordance with Technical Specification 3.7.7. This was reported pursuant to Technical Specification 6.9.1.13.b.

In our previous report we did not give an estimated restoration date. The purpose of this report is to provide an estimated date of restoration of June 30, 1983. Attached is LER 83-041/99 X-1, which is a final report.

Yours truly,


for J. P. McGaughy Jr.

JPM:sap
Attachment

cc: (See Next Page)

TE 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0255

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555