



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4001

John L. Skolds
Senior Vice President
Nuclear Operations

August 2, 1994
Refer to: RC-94-0205

Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Mr. G. F. Wunder

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION (VCSNS)
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
TRANSMITTAL OF RESPONSE TO NRC GENERIC LETTER 93-04

The SCE&G letter to NRC Document Control Desk dated November 8, 1993 (ref. RC-93-0283) discussed Rod Control System enhancements proposed by the Westinghouse Owners Group (WOG) for the long-term clarification of this issue, and committed to provide the NRC with a follow-up correspondence prior to our next refueling outage (which is scheduled to begin in the fall of 1994) outlining the actions to be taken and a schedule for implementation.

SCE&G hereby submits its follow-up response as committed to in correspondence RC-93-0283. Prior to the end of refueling 9, which is scheduled to begin in the Spring of 1996, SCE&G will implement the current order timing changes to the Rod Control System and an additional current order surveillance as recommended by the WOG. This schedule is consistent with that recommended by the WOG (ref. WOG-94-085, dated 6/13/94), which suggested implementation during the first refueling after January 1, 1995.

Should you have any questions, please call at your convenience.

Very truly yours,

John L. Skolds

RKM:rkm

c: O. W. Dixon
R. R. Mahan
R. J. White
S. D. Ebnetter
G. F. Wunder

NUCLEAR EXCELLENCE - A SUMMER TRADITION!



9408090253 940802
PDR ADDCK 05000395
PDR

A030
1/0

Document Control Desk Letter
GL 93-04
Page 2 of 2

General Managers
NRC Resident Inspector
J. B. Knotts Jr.
RTS (LTR930004)
File (815.14)
CFS