



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401-1927
Telephone (612) 330-5500

August 2, 1994

US Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Instantaneous Trip of 480 VAC MCCBs Do Not Meet
Acceptance Criteria Due to Manufacturer's Design

A supplemental report for the voluntary Licensee Event Report submitted on April 22, 1994 is attached. This supplemental report corrects an error concerning the labeling of the axes for the graph of "Instantaneous Trip Settings vs Actual Current to Trip" provided in the original event report. This letter contains no new NRC commitments, nor does it modify any prior commitments.

Please contact Marv Engen, Sr Licensing Engineer, at (612) 295-1291 if you require further information.

Marv Engen for ROA

Roger O Anderson
Director
Licensing and Management Issues

c: Regional Administrator - III, NRC
NRR Project Manager, NRC
Sr Resident Inspector, NRC
State of Minnesota
Attn: Kris Sanda

000074

9408090278 940802
PDR ADDCK 05000263
S PDR

1027