

ATTACHMENT 2

PEACH BOTTOM ATOMIC POWER STATION  
UNITS 2 AND 3

Docket Nos. 50-277  
50-278

License Nos. DPR-44  
DPR-56

TECHNICAL SPECIFICATION CHANGES

List of Attached Pages

Unit 2

Unit 3

234b

234b

## LIMITING CONDITIONS FOR OPERATION

## SURVEILLANCE REQUIREMENTS

## 4.11.D.3

Visual inspection of snubbers required to be operable under the provisions of 3.11.D.1 shall verify that 1) there are no indications of damage or impaired operability, 2) attachments to the foundations or supporting structure are functional, and 3) fasteners for the attachment of the snubber to the component and to the snubber anchorage are functional.

Snubbers which appear to be inoperable as a result of visual inspections shall be classified as unacceptable and may be reclassified acceptable for the purpose of establishing the next visual inspection interval, providing that 1) the cause of the rejection is clearly established and remedied for that particular snubber and for other generically susceptible snubbers; and 2) the affected snubber is functionally tested in the as found condition and determined operable per Specification 4.11.D.7 or 4.11.D.8, as applicable. All snubbers found connected to an inoperable common hydraulic fluid reservoir shall be counted as unacceptable for determining the next inspection interval. A review and evaluation shall be performed and documented to justify continued operation with an unacceptable snubber. If continued operation cannot be justified, the snubber shall be declared inoperable and the Limiting Conditions for Operation shall be met.

## 4.11.D.4

## Functional Test

- \*a) Once each operating cycle, during shutdown, a representative sample of 10% of each type of (mechanical or hydraulic) snubber required to be operable under the provisions of 3.11.D.1 shall be functionally tested either in place or in a bench test. For every unit found to be inoperable an additional 10% of that type of snubber shall be functionally tested until no more failures are found or all snubbers of that type have been tested. The functional test requirements for mechanical

DELETE

\* Performance of 4.11.D.4(a) with an operating cycle of 732 days is approved for the operating cycle following refueling outage 2R010 only.

## LIMITING CONDITIONS FOR OPERATION

## SURVEILLANCE REQUIREMENTS

## 4.11.D.3

Visual inspection of snubbers required to be operable under the provisions of 3.11.D.1 shall verify that 1) there are no indications of damage or impaired operability, 2) attachments to the foundations or supporting structure are functional, and 3) fasteners for the attachment of the snubber to the component and to the snubber anchorage are functional.

Snubbers which appear to be inoperable as a result of visual inspections shall be classified as unacceptable and may be reclassified acceptable for the purpose of establishing the next visual inspection interval, providing that 1) the cause of the rejection is clearly established and remedied for that particular snubber and for other generically susceptible snubbers; and 2) the affected snubber is functionally tested in the as found condition and determined operable per Specification 4.11.D.7 or 4.11.D.8, as applicable. All snubbers found connected to an inoperable common hydraulic fluid reservoir shall be counted as unacceptable for determining the next inspection interval. A review and evaluation shall be performed and documented to justify continued operation with an unacceptable snubber. If continued operation cannot be justified, the snubber shall be declared inoperable and the Limiting Conditions for Operation shall be met.

## 4.11.D.4

## Functional Test

\*a) Once each operating cycle, during shutdown, a representative sample of 10% of each type of (mechanical or hydraulic) snubber required to be operable under the provisions of 3.11.D.1 shall be functionally tested either in place or in a bench test. For every unit found to be inoperable an additional 10% of that type of snubber shall be functionally tested until no more failures are found or all snubbers of that type have been tested. The functional test requirements for mechanical

DELETE

\* Performance of 4.11.D.4(a) with an operating cycle of 732 days is approved for the operating cycle following refueling outage 3R09 only.