



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

SAMUEL F. MANNO  
VICE PRESIDENT  
NUCLEAR CONSTRUCTION

October 22, 1982  
(82-603)

Office of Inspection and Enforcement  
Region I  
Attention: Mr. R. W. Starostecki, Director  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406


Re: Nine Mile Point Unit 2  
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is an interim 30 day report in accordance with 10CFR50.55(e) for the deficiency concerning valves manufactured by Clow Corporation. This condition was reported via telephone to Mr. Wiggins of your staff on September 23, 1982, as a potentially reportable deficiency.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION

  
Samuel F. Manno  
Vice President  
Nuclear Construction

/djm  
Enclosure  
cc: Director of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Mr. R. D. Schulz, Resident Inspector

8211020528 821022  
PDR ADOCK 05000410  
S PDR

IE27

NIAGARA MOHAWK POWER CORPORATION  
Nine Mile Point Unit 2  
Docket No. 50-410

Interim Report for a Potentially  
Reportable Deficiency Under  
10CFR50.55(e) Regarding Clow Valves

Description of the Deficiency

Clow Corporation has advised Stone & Webster Engineering Corporation that 16 valves shipped to the Nine Mile Point Unit 2 site have missed heat treatment as required by ASME Code. In accordance with ASME Code (1974 edition), subparagraphs NC-4651(b) and ND-4651(b), heat treatment is required for carbon steel pipe or formed portions of pumps or valves with a wall thickness greater than 3/4 inch included in Group P - number 1 in Section IX that have been cold bent or formed.

The valve bodies for the valves in question were manufactured from SA515 Grade 70 carbon steel plate. The thickness of the plate was greater than 3/4 inch. The plate was rolled into hollow cylindrical form by cold working.

The matter is still under investigation. A final report will be submitted by March 31, 1983.