



State of New Jersey  
Department of Environmental Protection

Robert C. Shinn, Jr.  
Commissioner

Division of Environmental Safety, Health,  
and Analytical Programs  
Radiation Protection Programs  
Bureau of Nuclear Engineering  
CN 415  
Trenton, New Jersey 08625-0415  
Tel (609) 987-2032  
Fax (609) 987-6354

August 2, 1994

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Gentlemen:

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Technical Specification Change Request No. 216  
Automatic Depressurization System Relief Valve  
Setpoint Change

On June 15, 1994, GPU Nuclear Corporation, licensee of the Oyster Creek Nuclear Generating Station, submitted the subject amendment to the Nuclear Regulatory Commission. The proposed amendment would revise Technical Specification Section 2.3.D to change the setpoints "Reactor High Pressure, Relief Valve Initiation" by increasing the setpoint value by 15 psig for each of the Electromatic Relief Valves in the Automatic Depressurization System.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering (BNE) reviewed the above amendment in accordance with the requirements of 10CFR50.91(b). The BNE has no comment on the proposed change.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent Tosch, Manager  
Bureau of Nuclear Engineering

9408090412 940802  
PDR ADOCK 05000219  
P PDR

New Jersey is an Equal Opportunity Employer  
Recycled Paper

ADD 1/0

c: Jill Lipoti  
Assistant Director, Radiation Protection Programs  
N.J. DEP

D. Chawaga  
NRC Region I State Liaison Officer

A. Dromerick  
NRC Sr. Project Manager

L. Briggs  
NRC Sr. Resident Inspector

M. Laggart  
GPU Nuclear