



# MISSISSIPPI POWER & LIGHT COMPANY

*Helping Build Mississippi*

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 31, 1983

J. B. RICHARD  
SENIOR VICE PRESIDENT - NUCLEAR

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 2900  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Special Report 83-040/0 - Fire  
Rated Penetrations Opened  
to Implement Design Change  
Packages  
AECM-83/0310

Beginning on April 24, 1983, the fire rated penetrations listed on the attached page were opened to implement design change packages. Hourly fire watches were established within one hour and will be maintained for the duration of the planned maintenance activities in accordance with Technical Specification 3.7.7.

This condition has no affect on the health and safety of the public and does not constitute a threat to plant safety. The work tasks are expected to be completed by July 1, 1983. This is reported as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,

JBR:sap  
Attachment

cc: (See Next Page)

8306090134 830531  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22  
11

83 JUN 6 9:23  
USNRC REGION II  
ATLANTA, GEORGIA

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0310

Page 2

cc: Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Beginning on April 24, 1983, the following fire rated penetrations were opened to implement design change packages:

<u>PENETRATIONS</u>	<u>INCIDENT REPORT #</u>
CE 32G	83-04-86
CE 28G	83-04-90
CE 352G	83-04-90
CE 26E	83-04-92
CE 22G	83-04-99
CE 183G	83-04-99
 <u>FIRE DAMS</u>	
L018/LA41	83-04-88
L019/LA40	83-04-88
L045/LA41	83-04-88
L022/LA40	83-04-88
L035/LA30	83-04-88
L035/LA33	83-04-88
L035/LA38	83-04-88
L022/LA39	83-04-88
L035/LA17	83-04-88
L035/LA20	83-04-88
L045/LA14	83-04-88
L048/LA39	83-04-88
L070/LA31	83-04-88
L071/LA31	83-04-88
L075/LA31	83-04-88
L076/LA31	83-04-88
L082/LA54	83-04-88
L065/LA54	83-04-88
L088/LA18	83-04-91
L090/LA1	83-04-91
L094/LA57	83-04-91
L094/LA37	83-04-91
L01/LA52	83-04-94
L084/LA7	83-04-94
L049/LA16	83-04-94
L085/LA0	83-04-94
L049/LA22	83-04-100
L034/LA21	83-05-03
L035/LA1	83-05-03