



Carolina Power & Light Company

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

June 1, 1983

FILE: B09-13510C
SERIAL: BSEP/83-1669


Mr. James P. O'Reilly, Administrator
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1
DOCKET NO. 50-325
LICENSE NO. DPR-71
SPECIAL REPORT FOR TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During the ongoing Unit No. 1 refueling outage, a fire barrier LCO was initiated on April 26, 1983, for an Augmented Off-Gas Building (AOG) door. The door, No. 105, was opened to facilitate the installation of a plant modification. Due to the amount of work involved with this modification, the seven-day specified time frame of the subject LCO has been exceeded. Until the completion of the involved modification work and cancellation of the subject LCO, appropriate stationed fire watches will remain in effect.

Very truly yours,


C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/joh/LETJH1

Enclosure

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8306090136 830601
PDR ADOCK 05000325
S PDR

OFFICIAL COPY

IE 22
1/0

USNRC REGION I
ATLANTA, GEORGIA
83 JUN 6 P9:23