



Carolina Power & Light Company

P. O. Box 101, New Hill, North Carolina 27562  
June 1, 1983

FILE: SH N-2/18  
Item 119

MQAH 83-009

USNRC REGION II  
ATLANTA, GEORGIA

83 JUN 6 9:24

Mr. James P. O'Reilly  
United States Nuclear Regulatory Commission  
Region II  
101 Marietta Street, Northwest  
Atlanta, Georgia 30303

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT 1  
DOCKET NO. 50-400  
SEISMIC CLASS 1 ELECTRICAL, HVAC AND CONDUIT SUPPORTS

Dear Mr. O'Reilly:


This is to confirm the June 1, 1983 telephone conversation between Mr. N. J. Chiangi and Mr. A. Hardin. Mr. Hardin was informed that the March 3, 1983 potentially reportable item, pertaining to Seismic Class 1 Electrical, HVAC and Conduit supports that were fabricated and installed on site and accepted by a Quality Control inspector, no longer with CP&L, and were not in accordance with design documents, has been evaluated and considered not to be reportable per the provisions of 10CFR50.55(e).

Thank you for your consideration in this matter.

Yours very truly,

NJC/mt

cc: Mr. G. Maxwell  
Mr. V. Stello

  
N. J. Chiangi - Manager  
Quality Assurance/Quality Control  
Harris Plant

OFFICIAL COPY

8306090251 830601  
PDR ADOCK 05000400  
S PDR

IE 27  
110