

PA Department of Environmental Resources
Bureau of Radiation Protection
Division of Nuclear Safety

REPORT NO. 50-289/PA-94-02

DOCKET NO. 50-289

LICENSE NO. DPR-50

LICENSEE: GPU Nuclear
Correspondence Control Desk
P.O. Box 480
Middletown, PA 17057

FACILITY NAME: Three Mile Island Nuclear Station, Unit No. 1

INSPECTION AT: Londonderry Township, Dauphin County

INSPECTION CONDUCTED:

INSPECTOR:

David E. Ney
D.E. Ney, Nuclear Engineer

July 18, 1994
Date

R. J. Barkanic
R. J. Barkanic, Nuclear Engineer

7/18/94
Date

APPROVED BY:

R. R. Janati
R. R. Janati, Chief
Division of Nuclear Safety

7/18/94
Date

Inspection Summary: Inspection on June 27, 1994, Inspection Report
No. 50-289/PA-94-02

Areas Inspected: Announced inspection of the licensee's low level
radioactive waste shipment to the burial site including: shipping
documentation, package inspection, labeling, marking, placarding,
vehicle inspection, radiation and contamination surveys.

Results: No violations or deviations were identified.