

Iowa Electric Light and Power Company

May 27, 1983

DAEC-83- 407

Mr. James G. Keppler
Regional Administrator
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

Subject: Prompt Notification of a
Reportable Occurrence

File: A-118a, TE-2

Dear Mr. Keppler:

This letter, telecopied to your office, is intended to satisfy the requirement for prompt notification of a Reportable Occurrence in accordance with Specification 6.11.2.a of the Duane Arnold Energy Center Technical Specifications.

Technical Specification paragraph(s) violated: 3.7.A.6(c)

Description of Occurrence:

At 1346 hours, on May 27, 1983, both divisions of the hydrogen/oxygen analyzers were determined to be inoperable. In accordance with the above Technical Specification, an orderly shutdown was commenced. At 1630 hours on May 27, 1983 the 'A' system was returned to operable status and the shutdown was terminated.

Very truly yours,

BR York for

Daniel L. Mineck
Plant Superintendent - Nuclear
Duane Arnold Energy Center

gak
DLM/GAR/pf

cc: NRC Resident Inspector

JUN 3 1983

8306100103 830527
PDR ADOCK 05000331
S PDR

*TE29
1/0*