

Public Service
Electric and Gas
Company

Stanley LaBruna

Public Service Electric and Gas Company

P.O. Box 236, Hancocks Bridge, NJ 08038 609-339-1700

Vice President - Nuclear Engineering

AUG 03 1994

NLR-N94136

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Gentlemen:

CONFIRMATORY RESPONSE TO BULLETIN 93-02, SUPPLEMENT 1
DEBRIS PLUGGING OF EMERGENCY COOLING SUCTION STRAINERS
FACILITY OPERATING LICENSE NPF-57
HOPE CREEK GENERATING STATION
DOCKET NO. 50-354

NRC Bulletin 93-02, Supplement 1 was issued to inform licensees of the most recent information regarding the vulnerability of emergency core cooling system suction strainers to clogging during a loss of coolant accident. Boiling water reactor licensees were requested to take actions to provide training for operators and emergency response personnel and enhanced procedural guidance for ECCS strainer clogging indication and response actions.

Hope Creek responded to this Bulletin supplement by letter to the NRC dated April 19, 1994. In this letter Hope Creek committed to complete these actions by various dates, the latest which was July 8, 1994 (Completion of Operational Experience Feedback sessions). The "Reporting Requirements" section of Bulletin 93-02, Supplement 1 requested that a report be submitted within 30 days of completion of the requested actions confirming their completion.

This letter fulfills this reporting requirement. All actions committed to in the Hope Creek response to Bulletin 93-02, Supplement 1 have been completed, except for one ongoing commitment to follow this issue through the BWR Owners Group ECCS Strainer Committee. We continue to do this.

038041

9408150029 940803
PDR ADOCK 05000354
P PDR

JEN


AUG 03 1994

Document Control Desk
NLR-N94136

2

Should you have any further questions in this regard, please do not hesitate to contact us.

Sincerely,



C Mr. T. T. Martin, Administrator - Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Mr. J. C. Stone, Licensing Project Manager - Hope Creek
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Rockville, MD 20852

Mr. C. Marschall (S09)
USNRC Senior Resident Inspector

Mr. K. Tosch, Manager, IV
NJ Department of Environmental Protection
Division of Environmental Quality
Bureau of Nuclear Engineering
CN 415
Trenton, NJ 08625

STATE OF NEW JERSEY)
) SS.
COUNTY OF SALEM)


S. LaBruna, being duly sworn according to law deposes and says:

I am Vice President - Nuclear Engineering of Public Service Electric and Gas Company, and as such, I find the matters set forth in the above referenced letter, concerning the Hope Creek Generating Station, are true to the best of my knowledge, information and belief.



Subscribed and Sworn to before me

this ^{3rd/KJB} 25th day of August, 1994.



Notary Public of New Jersey

My Commission expires on _____

KIMBERLY JO BROWN
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires April 21, 1998