



Wisconsin Electric POWER COMPANY

231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

June 6, 1983

Mr. J. G. Keppler, Regional Administrator
Office of Inspection and Enforcement,
Region III
U. S. NUCLEAR REGULATORY COMMISSION
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Dear Mr. Keppler:

DOCKET NOS. 50-266 AND 50-301
RESPONSE TO IE BULLETIN 83-03
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

IE Bulletin 83-03, dated March 10, 1983, discussed check valve failures in the raw water cooling systems of diesel generators and directed Licensees to report on the verification of the integrity of the valve internals for such check valves. Licensees were also directed to include diesel generator cooling water check valves in their Section XI pump and valve inservice test program and to report to the NRC with a listing of these check valves. We are hereby informing you that the diesel generator cooling water flow paths at the Point Beach Nuclear Plant have been inspected and we have verified that there are no check valves in the flow path of cooling water for the diesel generators.

Very truly yours,

Executive Vice President

Sol Burstein

Copies to NRC Resident Inspector
NRC Document Control Desk,
Washington, D. C. (original)

Subscribed and sworn to before me
this 6th day of June 1983.

Notary Public, State of Wisconsin

My Commission expires July 17, 1983

IE 11
110

8306130146 830606
PDR ADOCK 05000266
PDR