

Iowa Electric Light and Power Company

June 8, 1983
NG-83-1912

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

PRINCIPAL STAFF			
RA		ENF	
D/RA		SCS	
A/RA		PAO	
DPRP		SLO	
DE		RC	
ML			
OL		FILE	

orig 1 ✓

Subject: Duane Arnold Energy Center
Docket No: 50-331
Op. License No: DPR-49
National Pollutant Discharge Elimination System
(NPDES) Violation Report
Reference: Letter, L. Root to H. Denton, "License Amendment
84 Regarding Water Quality Requirements,"
NG-83-1424, April 25, 1983.

Dear Mr. Keppler:

Per our referenced letter, Iowa Electric Light and Power Company agreed to submit to your office copies of all NPDES violations reports. Transmitted herewith, is a copy of the monthly monitoring report for April. This report shows a monthly average suspended solids effluent concentration of 34 milligrams per liter, which exceeds our permitted monthly average of 30 milligrams per liter. The daily limit of 45 milligrams per liter was not exceeded. The violation was due to the large number of personnel on-site to support the recent refueling outage. We expect the discharge concentrations to return to within the permitted levels upon completion of the outage, when personnel levels return to normal.

Please contact this office if you have any questions pertaining to this matter.

Very truly yours,

B. W. McLaughly

Richard W. McLaughly
Manager, Nuclear Division

RWM/RAB/dmh*
Attachment

cc: R. Browning
L. Liu
S. Tuthill
H. Denton
F. Apicella
NRC Resident Office
Commitment Control No. 83-0069

8306130375 830608
PDR ADCK 05000331
S PDR

JUN 10 1983

13:07