

11. Identification of Change

Page 17.1-15 of the SNUPPS Standard Plant PSAR

Reason for Change

The revised page reflects the fact that KG&E has incorporated into the QA Program a commitment to Regulatory Guide 1.146 made in response to NRC Generic Letter 81-01 dated 5/4/81.

Basis for Concluding that Revised Program Satisfies
10CFR50 Appendix B

This additional commitment to the program satisfies 10CFR50 Appendix B.

SNUPPS

experience may be certified based on documented written examinations and evaluations of actual work proficiency.

- h. NRC Regulatory Guide 1.64 "Quality Assurance Requirements for the Design of Nuclear Power Plants." (10/73)
- i. NRC Regulatory Guide 1.74 "Quality Assurance Terms and Definitions." (2/74)
- j. NRC Regulatory Guide 1.88 "Collection Storage and Maintenance of Nuclear Power Plant Quality Assurance Records." (10/76)

- m k. ANSI N45.2.5-1974 "Supplementary Quality Assurance Requirements for Installation, Inspection, and Testing of Structural Concrete and Structural Steel During the Construction Phase of Nuclear Power Plants."

The recommendations of this regulatory guide are met, with the exception of Section 5.4(1) of ANSI N45.2.5-1974. Bolts are tightened using direct tension indicators in accordance with AISC Specification for Structural Joints Using ASTM A325 or A490 Bolts, approved May 8, 1974. As a result, the requirement for the acceptance of tightened bolt assemblies is: "the length of the bolts shall be such that the point of the bolt will be flush with or outside of the face of the nut when completely installed."

- k X. NRC Regulatory Guide 1.116, "Quality Assurance Requirements for Installation, Inspection, and Testing of Mechanical Equipment and Systems." (6/76)

1. See insert

- n X. ANSI N45.2.12 (Draft 3, Rev. 4 - February 22, 1974) "Requirements for Auditing of Quality Assurance Programs for Nuclear Power Plants."

- o X. ANSI N45.2.13 (Draft 2, Rev. 4 - April, 1974) "Quality Assurance Requirements for Control of Procurement of Items and Services for Nuclear Power Plants," including Regulatory staff comments and supplementay guidance, Section D of the "Gray Book" (Guidance on Quality Assurance Requirements During Design and Procurement Phase of Nuclear Power Plants, Rev. 1).

Codes, standards, AEC Regulatory Guides, and regulations are considered by the SNUPPS QA Committee to determine their effect on the SNUPPS utilities' quality assurance program and, as appropriate, are incorporated or referenced in the SNUPPS Standard QA Manual.

Insert

1. NRC Regulatory Guide 1.146 "Qualification of Quality Assurance Program Audit Personnel for Nuclear Power Plants." (8/80)

11.