

SUPPLEMENTARY INFORMATION TO
LER 83-010/99 X-1

Mississippi Power & Light Company
Grand Gulf Nuclear Station - Unit 1
Docket No. 50-416

Technical Specification Involved: 3.7.7
Reported Under Technical Specification: 6.9.2

Event Narrative:

This is an update to a previous report submitted on February 7, 1983. The event for which the report was submitted is described in the following paragraph.

During an inspection of completed work which corrected fire protection deficiencies on redundant raceways/cables (Ref. LER 82-106/01 T-0), Field Engineering identified similar deficiencies which were not previously identified by the Architect Engineer but which were a result of incomplete construction. LCO's 83-0018, 83-0019, and 83-0020 were entered on January 5, 1983, to establish fire watches in the Auxiliary Building, Turbine Building and Control Building areas which were not previously covered under LCO 83-0036 (Ref. LER 82-106/01 T-0).

Maintenance work authorizations were issued to correct the deficiencies. The purpose of this report is to provide a revised estimated completion date of July, 1983.



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

June 2, 1983

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Redundant
Division Raceway Fire
Protection Deficiencies
Discovered
LER 83-010/99 X-1
AECM-83/0312

This letter submits an update to a previous report submitted on February 7, 1983. The event for which the report was submitted occurred on January 5, 1983, when during an inspection of completed work which corrected fire protection deficiencies on redundant raceways/cables, it was noted that there were similar deficiencies in the Auxiliary Building, Turbine Building, and Control Building. Fire watches were established in accordance with Technical Specification 3.7.7.a. The event was reported pursuant to Technical Specification 6.9.2.

Maintenance work authorizations were issued to correct the deficiencies. The purpose of this report is to provide a revised estimated completion date of July, 1983. Attached is LER 83-010/99 X-1.

Yours truly,

J.P. McGaughy
for J.P. McGaughy

JPM:sap
Attachment

cc: (See Next Page)

OFFICIAL COPY

IE 22

1/1

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0312

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555