



GPU Nuclear Corporation  
Post Office Box 480  
Route 441 South  
Middletown, Pennsylvania 17057  
717 944-7621  
TELEX 84-2386  
Writer's Direct Dial Number:

June 8, 1983

5211-83-174

Office of Nuclear Reactor Regulation  
Attn: John F. Stolz, Chief  
Operating Reactors Branch No. 4  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555


Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
Operating License No. DPR-50  
Docket No. 50-289  
Reactor Coolant Pump Trip

Our letter of March 31, 1983 (5211-83-017) provided information on our decision to revise RCP trip criteria from 1600 psig ESAS to 25°F subcooling margin and to implement these changes under 10 CFR 50.59 in June, 1983.

The purpose of this letter as discussed between you and J. Wetmore, on May 18, 1983, is to advise you that we will join the other B&W Owners in an effort to perform supplemental generic analyses to quantify margins and to address more specifically the NRC staff guidelines contained in your letter of March 4, 1983. Consistent with other B&W Owners, we will provide supplemental information and a schedule of our future activities in July, 1983.

Sincerely,

  
M. D. Hukill  
Director, TMI-1

HDH:LWH:vjf

cc: B. Sheron  
J. Van Vliet  
R. Conte

8306140623 830608  
PDR ADOCK 05000289  
P PDR

DO18  
1/0