


THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

June 13, 1983
LOZ-83-0047

J. WILLIAMS, JR.
SENIOR VICE PRESIDENT
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e), ITEM S-10, MASONRY WALL
CONSTRUCTION NOT PER DESIGN SPECIFICATION
AND FSAR CRITERIA
W.O. 57300, JOB E-5590, FILE NO. 956C, S-10

This letter constitutes an interim report concerning the subject condition initially reported to the Commission on May 13, 1983 as a potentially reportable deficiency under the requirements of 10CFR50.55(e).

The subject condition was identified in Section 2.4.2.2 of NUREG-0969, "Report of the NRC Evaluation Team on the Quality of Construction at the Zimmer Nuclear Power Station" (April, 1983).

The potential deficiencies are; (1) unfilled collar joints, (2) discontinuous and missing joint reinforcements, (3) improper fire seal at top of walls.

The corrective action which CG&E will take to resolve this condition is expansion of the Quality Confirmation Program (QCP) to include this concern. A subsequent letter will address the details of the QCP expansion in this area.

Scheduling and completion of the corrective action items and submittal of the final report are indeterminate at this time due to continued scoping of the QCP Task. A follow-up report will be submitted to you by September 12, 1983.

8306210054 830613
PDR ADOCK 05000358
S PDR

JUN 15 1983


110
1827

Mr. J. G. Keppler
Regional Administrator
June 13, 1983
LOZ-83-0047
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
J. WILLIAMS, JR.
SENIOR VICE PRESIDENT

DJS/WM/cse

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
ATIN: W. F. Christianson
NRC Zimmer Project Inspector Region III
ATIN: E. R. Schweibinz