

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 FILSILS1 2 0001 00000000 0000 3 411111 4 5

LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 38

CON'T

01 L 6 05 000335 7 020383 8 022883 9

REPORT SOURCE 50 51 DOCKET NUMBER 58 59 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 During normal full power operation, CEA #66 dropped 56 inches to the core.

03 Action was taken per T.S.3.1.3.1.e. CEA #66 was returned to Group posi-

04 tion in 80 minutes and normal operation was resumed. This is the nine-

05 teenth occurrence of a dropped CEA from an unknown cause. (See LERs 77-6,

06 78-18, 78-20, 78-46, 79-2, 79-27, 80-10, 80-32, 80-40, 80-52, 81-20, 81-27,

07 81-34, 82-28, 82-51, 82-61, 82-69, 83-06.) The health and safety of the

08 public were not affected by this event.

09

SYSTEM CODE R B 11 CAUSE CODE X 12 CAUSE SUBCODE Z 13 COMPONENT CODE C D R V E 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16

LER/RO REPORT NUMBER 17 EVENT YEAR 8 3 SEQUENTIAL REPORT NO. 0 0 7 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN Z 18 FUTURE ACTION Z 19 EFFECT ON PLANT B 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 6 ATTACHMENT SUBMITTED N 23 NRC-4 FORM SUB. N 24 PRIME COMP SUPPLIER N 25 COMPONENT MANUFACTURER C 4 9 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 No cause was found for the dropping of CEA #66. It has operated normally

11 since this event.

12

13

14

FACILITY STATUS E 28 % POWER 0 9 9 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32

ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

PUBLICITY N 44 DESCRIPTION NA 45 NRC USE ONLY

NAME OF PREPARER R. L. Hayes PHONE (305) 465-3550