

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 CADCP1 200-00000-0003 41111 5

CONT

01 REPORT SOURCE L 6050000275 7051483 8061383 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 Prior to fuel load, power to all Main Control Room Annunciators was lost during

03 construction activity in the annunciator cabinets. As a result, alarm status for

04 various Radiation Monitors, Seismic Monitoring Instrumentation and Fire Detection

05 Instrumentation was lost for a period of 32 minutes. All applicable Technical

06 Specification Action Statements were satisfied as listed in Supplemental Informa-

07 tion. This event has in no way affected the public health and safety. Reportable

08 per Technical Specification Section 6.9.1.13.b.

09 I F 11 A 12 E 13 A N N U N C 14 Z 15 Z 16

17 LER/NO REPORT NUMBER 83 21 22 010 24 25 03 26 L 30 31 0 32

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPSD-4 FORM SUB PRIME COMP. SUPPLIER COMPONENT MANUFACTURER 26

H 18 H 19 Z 20 Z 21 0000 Y 23 N 24 L 25 R 33 5 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Construction electrician inadvertently touched hot wire to ground, short circuit-

11 ing the panel. Power was restored and the annunciator returned to service. The

12 worker involved was admonished regarding the possible consequences of his actions

13 and to pay more careful attention to his work activities. Supplemental Informa-

14 tion is attached.

15 B 28 000 29 NA 30 A 31 Operator observation 32

16 Z 33 Z 34 NA 35 NA 36

17 000 37 Z 38 NA 39

18 000 40 NA 41

19 Z 42 NA 43

830621007B 830613
PDR ADOCK 05000275
S PDR

20 N 44 NA 45

NRC USE ONLY

NAME OF PREPARER William J. Kelly

PHONE: (805) 595-7351

ATTACHMENT TO LER 83-010/03L-0
PACIFIC GAS AND ELECTRIC COMPANY
DIABLO CANYON UNIT 1
DOCKET NO. 50-275, LICENSE NO. DPR-76

SUPPLEMENTAL INFORMATION

EVENT DESCRIPTION

With the loss of the Control Room Annunciators, the following instrumentation alarms were lost and Technical Specification Action Statements satisfied:

<u>INSTRUMENT</u>	<u>TECH. SPEC.</u>
Oily Water Separator Effluent Line Monitor (RM-3)	3.3.3.9
New Fuel Storage Area Monitor (RM-5)	3.3.3.1
Spent Fuel Pool Area Monitor (RM-9)	3.3.3.1
Containment Purge Noble Gas Activity Monitor (RM-14A & 14B)	3.3.3.10
Liquid Radwaste Effluent Line Monitor (RM-18)	3.3.3.9
Noble Gas Activity Monitor (RM-22)	3.3.3.10
Iodine Sampler Flow Rate Monitor (RM-24)	3.3.3.10
Steam Generator Blowdown Tank Vent Gross Activity Monitor (RM-27)	3.3.3.10
Seismic Monitoring Triaxial Time-History Accelograph Located At Containment Base Slab	3.3.3.3
Fire Detection Instrumentation	3.3.3.8

CORRECTIVE ACTIONS

Construction workers on vital plant equipment will receive additional training prior to work. Quality Assurance Department will audit to assure the implementation of training requirement.

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 919-372-6587

JAMES D. SHIFFER
MANAGER

DEPARTMENT OF NUCLEAR PLANT OPERATIONS
NUCLEAR POWER GENERATION

June 13, 1983

jm
Mr. John B. Martin, Regional Administrator
U.S. Nuclear Regulatory Commission, Region V
1450 Maria Lane, Suite 210
Walnut Creek, CA 94596-5368


Re: Docket No. 50-275, OL-DPR-76
Diablo Canyon Unit 1
Licensee Event Report 83-010/03L-0
Loss of Power to Main Annunciator Panels

Dear Mr. Martin:

Pursuant to Section 6.9.1.13.b of the Technical Specifications, Appendix A to the Diablo Canyon Unit 1 Operating License, the enclosed Licensee Event Report is submitted concerning a temporary loss of power to the control room main annunciator panels.

This event has in no way affected the public health and safety.

Very truly yours,



Enclosure

cc w/enc: Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director, Office of Management
Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Service List

1/1
IE-22
83-128