

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

NAME OF PREPARER

H.B. RAY

PHONE:

714-492-7700

NRC USE ONLY

017-926

ATTACHMENT TO LER 83-046
SOUTHERN CALIFORNIA EDISON COMPANY
SAN ONOFRE NUCLEAR GENERATING STATION
UNIT NO. 2, DOCKET NO. 50-361

SUPPLEMENTAL INFORMATION FOR CAUSE DESCRIPTION AND CORRECTIVE
ACTION

This will also be included in their monthly retraining session. As detailed in LER 83-015, plant design change studies (i.e., high and low limit alarms with either manual or automatic permissive) which will preclude recurrence of this event are still in progress.

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

RECEIVED
NRC

SCE

REGION V

TELEPHONE
(714) 492-7700

H. B. RAY

STATION MANAGER

June 6, 1983

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator


Dear Sir:

Subject: Docket No. 50-361
30-Day Report
Licensee Event Report No. 83-046
San Onofre Nuclear Generating Station, Unit 2

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-10 for San Onofre Unit 2, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.2.6 associated with the Reactor Coolant Cold Leg Temperature (T_C). Enclosed LER 83-046 addresses this event, including corrective actions and measures to prevent recurrence.

If there are any questions regarding the above, please contact me.

Sincerely,



Enclosure

111
IE-22

83-246

Mr. J. B. Martin

-2-

June 6, 1983

cc: A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)
R.J. Pate (USNRC Resident Inspector, Units 2 and 3)
J.P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission
Office of Management Information and Program Control (MIPC)

Institute of Nuclear Power Operations (INPO)