



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

June 3, 1983
(6781)

Mr. R. W. Starostecki, Director
U.S. Nuclear Regulatory Commission
Region I
Division of Project and Resident Programs
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 2
Docket No. 50-410

Dear Mr. Starostecki:

Enclosed is a 30-day final report in accordance with 10CFR50.55(e) concerning a QA inspector's certification. This condition was reported via telecon to Mr. Greenman of your staff on April 29, 1983, as a potentially reportable deficiency.

Very truly yours,

D. P. Dise
Vice President
Quality Assurance

DPD/TRL:jab
xc: Director of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. R. D. Schulz, Resident Inspector

8306210182 830603
PDR ADDCK 05000410
S PDR

IE27
11

NIAGARA MOHAWK POWER CORPORATION
NINE MILE POINT - UNIT 2
DOCKET NO. 50-410

Final Report Concerning
QA Inspector's Certification

Description of the Problem

At the time the problem was initially identified, we believed that Mr. N. Brown, a quality assurance inspector, was not certified for the activities performed by him. The problem was originally identified by Niagara Mohawk Power Corporation Quality Assurance surveillance at the site. The areas of concern included certain welding activities for electrical work.

A detailed review of Mr. N. Brown's qualification/certification records concerning past electrical work performed has been completed. The review has shown that Mr. Brown was properly certified in accordance with the Stone & Webster Engineering Corporation Quality Assurance program and ANSI N45.2.6 (1978) requirements at the time the activities in question were performed. The documentation for Mr. Brown's certification is available at the site for inspection.

We therefore believe that a deficiency does not exist, and hence, the criteria for reportability under 10CFR50.55(e) have not been met.