

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDIC 2 200-000000-00 341111 4 5
 8 9 14 15 25 26 57 CAT 58

CONT

01 REPORT SOURCE L 6 05000316 7 020383 8 022583 9
 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 DURING NORMAL OPERATION, THE CONTROL AIR TO CONTAINMENT ISOLATION VALVE (XCR-100) WAS
 03 CLOSED AND DEACTIVATED TO PERMIT TROUBLESHOOTING OF A POSSIBLE GROUND ON THE CLOSED
 04 INDICATION LIGHT. THIS SITUATION CAUSED THE VALVE (XCR-100) TO BE DECLARED INOPERABLE,
 05 THEREFORE, NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATION 3.6.3.1, TABLE 3.
 06 6-1 ITEM 80. THE APPLICABLE ACTION REQUIREMENTS WERE MET. THE PUBLIC HEALTH AND
 07 SAFETY WERE NOT AFFECTED.

08 8 9 80

09 SYSTEM CODE SID 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE ZZZZZZ 14 COMP SUBCODE Z 15 VALVE SUBCODE Z 16
 9 10 11 12 13 18 19 20
 17 LER NO REPORT NUMBER 83 21 22 23 24 26 27 28 29 30 31 32 REVISION NO. 0
 ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER Z 19 19 19 26
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 INVESTIGATION REVEALED THAT A FAULTY CABLE EXISTED CAUSING THE GROUND PROBLEM. A NEW
 11 CABLE WAS INSTALLED, MEGGERED AND TERMINATED. THE VALVE (XCR-100) WAS VERIFIED TO
 12 OPERATE CORRECTLY WITHIN THE REQUIRED TIME LIMIT AND RETURNED TO SERVICE.

13
 14 8 9 80

15 FACILITY STATUS E 28 % POWER 100 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION 32 OPERATOR OBSERVATION
 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36 NA
 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION 39 NA
 8 9 11 12 13 44 45 80

18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION 41 NA
 8 9 11 12 44 45 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION 43 NA
 8 9 10 44 45 80

20 PUBLICITY ISSUED N 44 DESCRIPTION 45 8303080519 830225 PDR ADOCK 05000316 S PDR NRC USE ONLY
 8 9 10 44 45 80

NAME OF PREPARER PALMER

PHONE 616/465/5901