



231 W Michigan, PO Box 2046, Milwaukee, WI 53201-2046

(414) 221-2345

August 9, 1994

NPL 94-0305

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, D.C. 20555

Gentlemen:

DOCKETS 50-266 AND 50-301
COMPLETION OF ACTIONS IN RESPONSE TO NRC GENERIC LETTER 89-10,
"SAFETY-RELATED MOTOR-OPERATED VALVE TESTING AND SURVEILLANCE"
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

NRC Generic Letter 89-10, dated June 28, 1989, requested that licensees provide additional assurance of the capability of safety-related motor-operated valves (MOV) and certain other MOVs in safety-related systems by performing certain actions. These actions included reviewing MOV design bases, verifying MOV switch settings, testing MOVs under design-basis conditions where practicable, improving evaluations of MOV failures, and trending MOV problems.

This letter is being submitted to inform you that Point Beach Nuclear Plant has implemented an MOV program and has completed all commitments made in response to this generic letter.

Please contact us if there are any questions.

Sincerely,

Michael F. Baumann for
Gary M. Krieser
Manager
Industry and Regulatory Services

Copies to: NRC Regional Administrator, Region III
NRC Resident Inspector

9408180098 940809
PDR ADOCK 05000266
P PDR

A064
10