

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C I C 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 3 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38CON'T
01 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 0 5 1 9 8 3 3 0 6 0 8 8 3 9
7 3 60 61 DOCKET NUMBER 69 74 EVENT DATE 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

012 DURING NORMAL OPERATIONS, FIRE DOOR #519 WOULD NOT LATCH. THIS CONSTITUTED AN
013 INOPERABLE PENETRATION FIRE BARRIER, NONCONSERVATIVE TO T.S. 3.7.10. THE ACTION
014 REQUIREMENTS WERE MET. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. THERE ARE NO
015 PREVIOUS OCCURRENCES ON THIS DOOR.

016

017

018

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE
019 A B 11 E 12 B 13 X X X X X X 14 Z 15 Z 16
7 3 9 10 11 12 13 14 15 16 17 18 19 20 21
17 LEAD REPORT NUMBER 18 EVENT YEAR 19 SEQUENTIAL REPORT NO. 20 OCCURRENCE CODE 21 REPORT TYPE 22 REVISION NO.
023 024 025 026 027 028 029 030 031 032
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
033 A 034 Z 035 Z 036 Z 037 0 0 0 0 038 N 039 N 040 A 041 X 042 9 043 9 044 9 045 9 046 047 25

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

010 THE STRIKE PLATE WAS REPLACED ON FIRE DOOR #519. THE DOOR CLOSER MECHANISM
011 WAS ADJUSTED AND THE DOOR OPERATED SATISFACTORILY.

012

013

014

FACILITY STATUS 1 POWER 2 OTHER STATUS 30 METHOD OF DISCOVERY 31 DISCOVERY DESCRIPTION 32
015 E 016 1 0 0 0 017 NA 018 A 019 MANAGERIAL TOUR AND INSPECTION
7 3 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32ACTIVITY CONTENT 33 RELEASED OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36
016 Z 017 Z 018 NA 019 NA
7 3 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32PERSONNEL EXPOSURES 37 NUMBER 38 TYPE 39 DESCRIPTION 39
017 0 0 0 018 Z 019 NA
7 3 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32PERSONNEL INJURIES 40 NUMBER 41 DESCRIPTION 41
018 0 0 0 019 NA
7 3 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32LOSS OF OR DAMAGE TO FACILITY 42 TYPE 43 DESCRIPTION 43
019 Z 020 NA
7 3 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32PUBLICITY 44 ISSUED DESCRIPTION 45
020 N 021 NA
7 3 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER D. ROBINSON

PHONE: 616-465-5901

8306210279 830608
PDR ADOCK 05000315
S PDR

NRC USE ONLY