

THE CINCINNATI GAS & ELECTRIC COMPANY



CINCINNATI, OHIO 45201

June 13, 1983

LOZ-83-0048

J. WILLIAMS, JR.
SENIOR VICE PRESIDENT
NUCLEAR OPERATIONS

Docket No. 50-358

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J.G. Keppler
Regional Administrator

Gentlemen:

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT 1
10CFR50.55(e), ITEM S-9, SOIL STRUCTURE AND
COMPACTION OUTSIDE POWER AREA NOT PER DESIGN
SPECIFICATION AND FSAR CRITERIA
W.O. 57300, JOB E-5590, FILE NO. 956C, S-9

This letter constitutes an interim report concerning the subject condition initially reported to the Commission on May 13, 1983 as a potentially reportable deficiency under the requirements of 10CFR50.55(e).

The subject condition was identified in Section 2.4.1.1 of NUREG-0969 "Report of the NRC Evaluation Team on the Quality of Construction at the Zimmer Nuclear Power Station" (April, 1983).

The potential deficiency is that "Soil structure and compaction outside the power block area was not monitored by a surveillance program during actual work to ensure any such areas do not interface with safety systems."

The proposed action is to provide a program which will identify all safety related structures and systems outside the power block where documentation is incomplete and/or missing. CG&E expects to submit a program to the NRC by September 15, 1983.

8306210294 830613
PDR ADOCK 05000358
S PDR

JUN 16 1983


IE27 1/p

Mr. J.G. Keppler
Regional Administrator
June 13, 1983
LOZ-83-0048
Page 2

We trust the above will be found acceptable as an interim report under 10CFR50.55(e).

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By 
J. WILLIAMS, JR.
SENIOR VICE PRESIDENT

DJS/WWM/sfr

cc: NRC Office of Inspection & Enforcement
Washington, D.C. 20555
NRC Senior Resident Inspector
ATTN: W.F. Christianson
NRC Zimmer Project Inspector, Region III
ATTN: E. R. Schweibinz