

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

PHONE 714/492-7700

NRC USE ONLY

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY

STATION MANAGER

RECEIVED
NRC

SCE

1983 JUN -9 PM 12:10

REGION V

TELEPHONE
(714) 492-7700

June 6, 1983

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:


SUBJECT: Docket Nos. 50-361 and 50-362
Prompt Report
Licensee Event Report No. 83-060 (Docket No. 50-361)
San Onofre Nuclear Generating Station, Units 2 and 3

Pursuant to the reporting requirements of Section 6.9.1.12.b of Appendix A Technical Specifications to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, this submittal provides the written confirmation of our prompt notification to the NRC on June 3, 1983, of a reportable occurrence involving improper cancellation of a continuous fire watch. This report also constitutes the 14-day followup report and a copy of Licensee Event Report (LER) 83-060 is provided.

Since the occurrence involves a shared system between Units 2 and 3, in accordance with NUREG-0161, a single Licensee Event Report (LER) for Unit 2, LER 83-060 (Docket No. 50-361) is provided.

If there are any questions regarding the above, please contact me.

Sincerely,



Enclosure: LER 83-060 (Unit 2)

111
IE-22
83-247

Mr. J. B. Martin

-2-

cc: R.J. Pate (USNRC Resident Inspector, Units 2 and 3)
A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)
P.J. Stewart (USNRC Resident Inspector, Units 2 and 3)

ATTACHMENT TO LER 83-060

SOUTHERN CALIFORNIA EDISON
SAN ONOFRE NUCLEAR GENERATING STATION

UNIT NO. 2, DOCKET NO. 50-361

In accordance with Section 3.7.8.2, Action 'a', of Appendix A to Technical Specifications of Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, continuous fire watches were established on the 70 foot level cable riser galleries on May 16, 1983, due to a planned outage of the deluge-water spray systems. On May 20, 1983, maintenance activity was performed on a Fire Detection Panel 2/3 L-237 which resulted in a second, separate requirement for a continuous fire watch for the galleries. On May 25, 1983, the Fire Detection Panel was returned to service.

On May 27, 1983, at 1745, the Fire Watch Coordinator, upon notification that the Fire Detection Panel had been returned to service, secured the fire watch although the deluge-water spray systems remained inoperative. On June 1, 1983, at 1021, a continuous fire watch was reinstated by the Fire Watch Coordinator in the galleries when the deluge-water spray system outage form was noted to still be in effect. On June 3, 1983, during a review of outage records the violation of Technical Specification Section 3.7.8.2 was recognized.