

CP&L

USNRC REGION II
ATLANTA, GEORGIA

Carolina Power & Light Company

83 FEB 28 A8:49

Brunswick Steam Electric Plant
P. O. Box 10429
Southport, NC 28461-0429

February 16, 1983

FILE: B09-13510A
SERIAL: BSEP/83-500

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II, Suite 3100
101 Marietta Street N.W.
Atlanta, GA 30303


BRUNSWICK STEAM ELECTRIC PLANT, UNIT NOS. 1 & 2
DOCKET NOS. 50-325 AND 50-324
LICENSE NOS. DPR-71 AND DPR-62
RESPONSE TO IE BULLETIN 82-04

Dear Mr. O'Reilly:

Carolina Power & Light Company has reviewed your letter dated December 3, 1982, transmitting IE Bulletin 82-04, Deficiencies in Primary Containment Electrical Penetration Assemblies, and hereby respond to the concerns of that bulletin for the Brunswick station.

The Brunswick station does not have the Bunker Ramo electrical penetrations referenced in the bulletin installed, in stock, or planned for future installation. The Brunswick station uses electrical penetrations supplied by Westinghouse.

Very truly yours,



P. W. Howe - Vice President
Brunswick Nuclear Project

RMP/mcg/LETCG1

cc: Mr. R. C. DeYoung
NRC Document Control Desk

8303210323 830216
PDR ADOCK 05000324
Q PDR

IE31

Mr. J. P. O'Reilly

-2-

February 16, 1983

P. W. Howe, having been first duly sworn, did dispose and say that the information contained herein is true and correct to his own personal knowledge or based upon information and belief.

Marsha M. Stone
Notary (Seal)

My commission expires: 3-22-87