

Georgia Power Company  
333 Piedmont Avenue  
Atlanta, Georgia 30308  
Telephone 404 526-6520

Mailing Address:  
Post Office Box 4545  
Atlanta, Georgia 30302

USNRC REGION II  
ATLANTA, GEORGIA



Georgia Power

the southern electric system

Power Generation Department

03 MAR 10 A10:00

NED-83-148

March 10, 1983

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II - Suite 2700  
101 Marietta Street, NW  
Atlanta, Georgia 30303

REFERENCE:  
RII: JPO  
50-321/50-366  
I&E Bulletin  
82-04

ATTENTION: Mr. James P. O'Reilly

GENTLEMEN:


Georgia Power Company hereby responds to I&E Bulletin 82-04 which was transmitted by letter dated December 3, 1982. This Bulletin addressed deficiencies present in hard epoxy electrical penetrations manufactured by the Bunker Ramo Company. Plant Hatch Units 1 and 2 do not presently utilize any Bunker Ramo penetration assemblies, nor are there any plans to use these items in the future. Therefore, no further action is planned by Georgia Power Company for Plant Hatch with regards to the subject bulletin.

This reply contains no proprietary information and may be placed in the NRC Public Document Room.


J. T. Beckham, Jr. states that he is Vice President of Georgia Power Company and is authorized to execute this oath on behalf of Georgia Power Company, and that to the best of his knowledge and belief the facts set forth in this letter are true.

GEORGIA POWER COMPANY

8303210361 830310  
PDR ADOCK 05000321 PDR  
G

By:   
J. T. Beckham, Jr.

Sworn to and subscribed before me this 10th day of March, 1983.



Notary Public, Georgia, State of Large  
My Commission Expires Aug. 26, 1986  
CBS/mb

Notary Public

Enclosure - None

xc: H. C. Nix, Jr.  
Senior Resident Inspector  
J. P. O'Reilly, (NRC-Region II)

IE31