

Arizona Public Service Company

P.O. BOX 21666 • PHOENIX, ARIZONA 85036

RECEIVED
NRC

50-528
50-529

1983 JUN 17 PM 12:20
June 8, 1983

ANPP-24003-BSK/RQT

REGION V

U. S. Nuclear Regulatory Commission
Region V
Creekside Oaks Office Park
1450 Maria Lane - Suite 210
Walnut Creek, CA 94596-5368

Attention: Mr. D. M. Sternberg, Chief
Reactor Projects Branch 1

Subject: Time Extension - DER 83-14
A 50.55(e) Potentially Reportable Deficiency Relating to
Diesel Generator Protective Relays By Westinghouse Failed Due
to Leaking Capacitors.
File: 83-019-026; D.4.33.2

Reference: (A) Telephone Conversation between A. D'Angelo and
R. Tucker on March 16, 1983
(B) ANPP-23504 dated April 14, 1983 (Interim Report)

Dear Sir:

The NRC was notified of a potentially reportable deficiency in
Reference (A), and an Interim Report was transmitted by Reference (B).
At that time, it was estimated that a Final Report would be available
by June 28, 1983.

Due to the extensive investigation and evaluation required, it is now
expected that this information will be finalized by August 31, 1983, at
which time a complete report will be submitted.

There is no new information or change to the Interim Report at this time.

Very truly yours,

E. E. Van Brunt

E. E. Van Brunt, Jr.
APS Vice President
Nuclear Projects Management
ANPP Project Director

EEVB/RQT:ru
cc: See Page 2

8306230318 830608
PDR ADOCK 05000528
S PDR

110
IF-27

U. S. Nuclear Regulatory Commission
Page 2

cc: Richard DeYoung, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

T. G. Woods, Jr.
G. C. Andognini
J. A. Roedel
D. B. Fasnacht
A. C. Rogers
B. S. Kaplan
W. E. Ide
J. Vorees
J. R. Bynum
P. P. Klute/D. D. Green
A. C. Gehr
W. J. Stubblefield
W. G. Bingham
R. L. Patterson
R. W. Welcher
R. M. Grant
D. R. Hawkinson
L. E. Vorderbrueggen
G. A. Fiorelli
S. R. Frost

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway - Suite 1500
Atlanta, Georgia 30339