

August 12, 1994

U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attn: Document Control Desk

Subject: Quad Cities Power Station Units 1 and 2;
NRC Docket Number 50-254 and 50-265;
NRC Inspection Report Numbers 50-254(265)/93025

Reference: E. Greenman letter to M. Wallace dated October 26, 1993,
transmitting Notice of Violation.
Inspection Report 50-254/93025; 50-265/93025

Enclosed is Commonwealth Edison's revision to the response to the Notice of Violation (NOV) transmitted with the referenced letter. The NOV cited four level IV violations involving; 1) missed 50.72 reporting, 2) inadequate corrective actions, 3) inadequate procedures and 4) inadequate test control of core spray valves.


In the response for the notice of violation for inadequate test control of core spray valves, the following commitment was made:

1) The test requirement to perform the high pressure seat leakage test each refueling outage will be added to the next revision of the IST program which is expected to be submitted by September 15, 1994.

The station is revising the above commitment to 5/15/95 to allow for the completion of the independent assessment of the IST program and to allow for all recommended procedure changes to be incorporated by this time.

If there are any questions or comments concerning this letter, please refer them to Ron Baumer, Regulatory Assurance at (319) 654-2241 extension 3102.

Respectfully,


L. J. Tucker
Technical Superintendent
Quad Cities Station

Attachment

cc: J. Martin, Regional Administrator, RIII
C. Patel, Project Manager, NRR
C. Miller, Senior Resident Inspector, Quad Cities

9408190214 940812
PDR ADOCK 05000254
PDR

TEC 1/0